CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 11/06/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 16-05-19

: GF Column Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 11/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	14/05/2019	11/06/2019	149.21 X 149.59 X 151.59	22320	**8.692**	611.1	27.4	27.7
Column Concrete	M25	14/05/2019	11/06/2019	150.60 X 149.19 X 150.98	22468	**8.542**	605.4	26.9	
Column Concrete	M25	14/05/2019	11/06/2019	149.21 X 151.17 X 149.22	22555	**8.525**	652.3	28.9	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Fax: 04472924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 21/05/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 16-05-19

: GF Column Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 21/05/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	14/05/2019	21/05/2019	150.72 X 150.34 X 151.55	22660	**8.569**	524.4	23.1	22.7
Column Concrete	M25	14/05/2019	21/05/2019	151.79 X 151.04 X 151.36	22927	**8.902**	518.2	22.6	
Column Concrete	M25	14/05/2019	21/05/2019	149.96 X 150.97 X 150.83	22639	**8.452**	503.4	22.2	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

: CP-2019-09-12-35

Date: 11/06/2019

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 16-05-19

: GF Column Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 11/06/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	14/05/2019	11/06/2019	149.42 X 150.72 X 151.29	22520	**8.692**	629.4	27.9	27.8
M25	14/05/2019	11/06/2019	150.32 X 150.73 X 150.31	22659	**8.542**	608.4	26.8	
M25	14/05/2019	11/06/2019	149.43 X 150.94 X 150.45	22555	**8.525**	646.9	28.7	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 21/05/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 16-05-19

: GF Column Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 21/05/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	14/05/2019	21/05/2019	151.51 X 150.67 X 151.76	22828	**8.569**	540.0	23.7	23.0
Column Concrete	M25	14/05/2019	21/05/2019	149.49 X 150.81 X 150.39	22545	**8.902**	504.6	22.4	
Column Concrete	M25	14/05/2019	21/05/2019	149.09 X 149.71 X 150.26	22319	**8.452**	511.4	22.9	

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 11/06/2019

: **CP-2019-09-12-35**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 16-05-19

: GF Column Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 11/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Column Concrete	M25	14/05/2019	11/06/2019	149.48 X 149.33 X 149.58	22321	**8.692**	604.9	27.1	27.2
Column Concrete	M25	14/05/2019	11/06/2019	151.47 X 150.63 X 151.41	22815	**8.542**	601.1	26.3	
Column Concrete	M25	14/05/2019	11/06/2019	150.02 X 149.80 X 150.64	22472	**8.525**	633.8	28.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

24526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 10/06/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 06-06-19

: GF Lintel Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Lintel Concrete	M25	03/06/2019	10/06/2019	150.54 X 150.19 X 150.21	22610	**8.569**	527.6	23.3	22.5
Lintel Concrete	M25	03/06/2019	10/06/2019	149.77 X 150.82 X 150.25	22587	**8.902**	499.7	22.1	
Lintel Concrete	M25	03/06/2019	10/06/2019	151.27 X 149.96 X 150.76	22684	**8.452**	501.5	22.1	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 01/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 06-06-19

: GF Lintel Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 01/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Lintel Concrete	M25	03/06/2019	01/07/2019	151.05 X 149.45 X 151.10	22574	**8.692**	617.1	27.3	27.4
Lintel Concrete	M25	03/06/2019	01/07/2019	150.35 X 150.25 X 151.92	22591	**8.542**	595.8	26.4	
Lintel Concrete	M25	03/06/2019	01/07/2019	149.02 X 149.40 X 151.14	22262	**8.525**	634.8	28.5	

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 10/06/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 06-06-19

: GF Lintel Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Lintel Concrete	M25	03/06/2019	10/06/2019	151.89 X 150.21 X 151.15	22815	**8.569**	530.0	23.2	22.7
Lintel Concrete	M25	03/06/2019	10/06/2019	149.98 X 151.25 X 150.61	22685	**8.902**	501.6	22.1	
Lintel Concrete	M25	03/06/2019	10/06/2019	150.70 X 150.81 X 149.98	22727	**8.452**	520.4	22.9	

FOR CIVIL Pro.

CIVIL PRO Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 01/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 06-06-19

: GF Lintel Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 01/07/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	03/06/2019	01/07/2019	151.05 X 149.45 X 151.10	22574	**8.692**	617.1	27.3	27.4
M25	03/06/2019	01/07/2019	150.35 X 150.25 X 151.92	22591	**8.542**	595.8	26.4	
M25	03/06/2019	01/07/2019	149.02 X 149.40 X 151.14	22262	**8.525**	634.8	28.5	

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

| Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 17/06/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 12-06-19

: GF Staircase Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 17/06/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	10/06/2019	17/06/2019	149.66 X 151.27 X 150.70	22638	**8.569**	523.5	23.1	22.9
M25	10/06/2019	17/06/2019	150.47 X 149.28 X 149.70	22463	**8.902**	514.0	22.9	
M25	10/06/2019	17/06/2019	149.18 X 149.27 X 151.38	22268	**8.452**	504.3	22.6	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

4526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 01/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 06-06-19

: GF Lintel Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 01/07/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	03/06/2019	01/07/2019	151.47 X 149.64 X 151.97	22666	**8.692**	617.0	27.2	27.7
M25	03/06/2019	01/07/2019	151.06 X 151.61 X 149.13	22902	**8.542**	617.5	27.0	
M25	03/06/2019	01/07/2019	150.64 X 151.84 X 151.59	22874	**8.525**	661.0	28.9	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 17/06/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 12-06-19

: GF Staircase Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 17/06/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	10/06/2019	17/06/2019	150.76 X 149.32 X 151.46	22512	**8.569**	525.1	23.3	22.8
M25	10/06/2019	17/06/2019	149.37 X 149.10 X 150.81	22270	**8.902**	490.5	22.0	
M25	10/06/2019	17/06/2019	150.68 X 149.18 X 150.85	22479	**8.452**	516.9	23.0	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

4526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 08/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 12-06-19

: GF Staircase Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 08/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Staircase Concrete	M25	10/06/2019	08/07/2019	149.96 X 149.36 X 149.65	22398	**8.692**	607.6	27.1	27.5
Staircase Concrete	M25	10/06/2019	08/07/2019	150.40 X 151.92 X 149.31	22850	**8.542**	604.1	26.4	
Staircase Concrete	M25	10/06/2019	08/07/2019	150.52 X 150.37 X 150.29	22633	**8.525**	652.1	28.8	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 23/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 18-07-19

: Sump Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 23/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
	M25	16/07/2019	23/07/2019	149.19 X 150.00 X 150.52	22377	**8.569**	523.9	23.4	22.8
	M25	16/07/2019	23/07/2019	149.13 X 149.42 X 149.28	22283	**8.902**	499.3	22.4	
	M25	16/07/2019	23/07/2019	150.80 X 151.77 X 149.47	22888	**8.452**	518.5	22.7	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

24526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 08/07/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

: 12-06-19

: GF Staircase Concrete

Size : 150X150X150 mm

Age : M25 / 28 Days Compressive Strength

IS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 08/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
GF Staircase Concrete	M25	10/06/2019	08/07/2019	149.48 X 149.95 X 150.43	22414	**8.692**	612.8	27.3	27.3
GF Staircase Concrete	M25	10/06/2019	08/07/2019	151.11 X 149.38 X 149.13	22572	**8.542**	588.4	26.1	
GF Staircase Concrete	M25	10/06/2019	08/07/2019	149.86 X 149.86 X 150.42	22458	**8.525**	640.0	28.5	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****